



DRIP VALVE: VALVE MAY BE OF ANY TYPE. IF VALVE HAS HOSE THREADS A NON-REMOVABLE VACUUM BREAKER MUST BE INSTALLED

NOTES:

1. IF METER IS TO BE ENCLOSED, REMOVABLE PANELS SHALL BE USED SO THAT ACCESS TO THE METER AND VALVES IS PROVIDED.
2. ACCESS PANEL OPENING MUST BE LARGER THAN METER FOR REMOVAL AND INSTALLATION.
3. IF ENCLOSED METER MUST BE 6" - 24" BACK FROM ENCLOSURE.
4. MINIMUM 12" OF CLEARANCE ABOVE METER.
5. METER SHALL NOT BE INSTALLED IN A CRAWL SPACE OR INACCESSIBLE AREA.
6. METER TO MEET MANUFACTURERS SPECIFICATIONS FOR UPSTREAM PIPE REQUIREMENTS.

Revised:
1. 06/12/2015
2. 09/22/2015
3.
4.

Drawing Name
WATER METER INSTALLATION TYPICAL

Drawing Number
UW-10
Date: 06/10/2015
Drawn Checked
JH VR

