



**NOTES:**

1. STAINLESS STEEL BANDS WILL BE SECURED TO THE MANHOLE WITH NON-CORROSIVE FASTENERS AND STAINLESS STEEL BOLTS.
2. ONE STAINLESS STEEL BAND WILL BE REQUIRED ON EACH FITTING AND 18" INTERVALS.
3. THE DROP PIPE WILL BE PLACED IN THE MANHOLE SO AS NOT TO INTERFERE WITH THE STEPS.
4.  $D2 = D1$
5. ALL MANHOLES MUST BE DAMP PROOF PER IDOT SPECIFICATIONS 1060 "WATER PROOFING MATERIALS" ALL INSIDE DROP MANHOLE MUST BE 5' I.D. STRUCTURES.
6. SERVICE LINE INVERT ELEVATION SHALL BE AT SPRING LINE OR CROWN OF MAIN LINE SEWER.

|               |
|---------------|
| Revised:      |
| 1. 06/12/2015 |
| 2.            |
| 3.            |
| 4.            |

|  |
|--|
| Drawing Name                                     |
| <b>STANDARD INSIDE DROP<br/>SANITARY MANHOLE</b> |

|                    |
|--------------------|
| Drawing Number     |
| <b>US-05</b>       |
| Date: 04/15/2007   |
| Drawn      Checked |
| EM          VR     |

