



**NOTES:**

1. ON EXISTING SEWER MAIN, CONNECTIONS SHOULD BE CORDED AND A NON SHEER SADDLE INSTALLED SEE STANDARD US-03.
2. PVC SDR 35 (MIN) OR DIP REQUIRED WHEN COVER IS LESS THAN 10'.
3. PVC SDR 26 (MIN) OR DIP REQUIRED WHEN COVER IS GREATER THAN OR EQUAL TO 10' AND LESS THAN 20'.
4. DUCTILE IRON REQUIRED WHEN COVER IS GREATER THAN OR EQUAL TO 20'.

Revised:
1. 06/12/2015
2.
3.
4.

Drawing Name
<b>SANITARY SERVICE RISER (DEPTH &gt;= 10')</b>

Drawing Number
<b>US-02</b>
Date: 05/29/2015
Drawn      Checked
JH          VR

