



PCC: USE PCC OR BAM
 BAM: USE BAM
 GRAVEL: USE CA-6 CRUSHED

ALL PIPES WILL HAVE A
 MIN. 4" CA-6 BEDDING

TRENCH BACK FILL MATERIAL (TBF)
 TO BE PLACED IN 6" COMPACTED
 LAYERS. USE CA-6 GRADE 8 OR 9
 AGGREGATE. COMPACT TO 90% OF
 MODIFIED PROCTOR.

LEGEND:

- 1 TEMPORARY STREET PATCHES DURING WINTER CONSTRUCTION SHALL BE 4" P.C. CONCRETE, IDOT CLASS SI OR A MIN. 3" OF UPM (COLD PATCH). PERMANENT PATCHES SHALL BE COMPLETED AS SOON AS POSSIBLE IN THE SPRING.
- 2 HMA BASE COURSE MUST BE AUTHORIZED BY THE CITY ENGINEER.
- 3 FOR CERTAIN UTILITY STREET CUTS, THE CITY ENGINEER MAY AUTHORIZE OR REQUIRE THE USE OF A CONTROLLED LOW-STRENGTH MATERIAL (CLSM) AS PER THE IDOT SPECIAL PROVISIONS.

Revised:
1. 06/12/2015
2.
3.
4.

Drawing Name
PAVEMENT CUT AND REPLACEMENT

Drawing Number
RD-06
Date: 05/19/2015
Drawn Checked
JH AW

