



NOTES:

1. IF METER IS TO BE ENCLOSED, REMOVABLE PANELS SHALL BE USED SO THAT ACCESS TO THE METER, VALVES, AND BACKFLOW DEVICE SHALL BE PROVIDED.
2. ACCESS PANEL OPENING MUST BE LARGER THAN METER AND BACKFLOW DEVICE FOR REMOVAL, INSTALLATION OR SERVICE.
3. IF ENCLOSED, METER MUST BE 6" - 24" BACK FROM ENCLOSURE.
4. PROVIDE MINIMUM 12" OF CLEARANCE ABOVE METER.
5. METER SHALL BE INSTALLED INSIDE THE HEATED PORTION OF THE BUILDING IN AN ACCESSIBLE LOCATION.
6. **METER SHALL NOT BE INSTALLED IN A CRAWL SPACE OR PIT.**
7. METER TO MEET MANUFACTURERS SPECIFICATIONS FOR UPSTREAM PIPE REQUIREMENTS.
8. EACH METER REQUIRES INDIVIDUAL WATER SERVICE LINE WITH SHUT OFF VALVE IN RIGHT OF WAY. (SEE UW-01 AND UW-04)
9. ELECTRIC SERVICE, METER BACKFLOW DEVICE JUMPER WIRE SHALL BE BASED ON THE CURRENT NATIONAL ELECTRICAL CODE (JUMPER NOT NEEDED FOR CPVC OR PEX PIPING)
10. BACKFLOW DEVICE PER ILLINOIS STATE PLUMBING CODE REQUIREMENTS

Revised:
1. 06/12/2015
2. 08/18/2023
3. 02/06/2025 JRG- ADDED NOTES AND PLAN VIEW
4.

Drawing Name

## WATER METER INSTALLATION WITH BACKFLOW PREVENTOR

Drawing Number	UW-11
Date:	06/10/2015
Drawn	Checked
JH	VR

