

Mobile Food Truck Inspections

1. Permit Applied for
2. LPG/CNG Systems – System has current stamps on tanks and are installed correctly and secured with approved means
3. Hood System – Hood suppression system is in place and properly covers the cooking components, has a current inspection by a certified Hood contractor.
4. Fire Protection System – External Horn Strobe installed on the customer serving side of the food truck and is tied in with the suppression system. Proof of install may be required. Extinguisher is properly mounted and tagged with a current inspection.
5. Means of Egress – Clear path to exit is not blocked and easily accessible
6. Electrical System – No use of extension cords, truck has a properly installed electrical system and is properly grounded, not open circuits or exposed wiring.
7. Detection and Alarm Systems – Smoke detectors / CO detectors etc are installed properly and in good working order.
8. Current License / Registration – Photo taken of license / registration and kept on file with inspection.
9. General Walk around to Ensure Trailer / components are in good working order